

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

LISTING No. 7260-1506:100 Page 1 of 1

CATEGORY: Beam Smoke Detection System

LISTEE: Siemens Building Technologies AG, \*Fire & Security Products  
Alte Landstrasse 411, CH-8708, Mannedorf, Switzerland  
Contact: Thomas Capaul 011-41-1-922 6111

DESIGN: Model DLO-1191 projected beam smoke detector. Unit consists of an emitter/receiver unit, Model DLA1191A detector module and Model DLB1191A base. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 18 – 28 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as projected beam smoke detector for use with separately listed compatible fire alarm control units.

\*05-14-03



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 14, 2003**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**